

**Illinois Commerce Commission
Pipeline Safety
Field Trip Report**

Operator: AMEREN ILLINOIS COMPANY	Operator ID#: 32513
Exit Meeting Contact: J.R. Jennings	Total Man Days: 1
Pipeline Safety Representative(s): Jim Watts	
Company Representative to Receive Report: Michael Fuller	<u>Emailed Date:</u>
Company Representative's Email Address: mfuller2@ameren.com	09/17/2013

Inspection Summary

Inspection Type	Location	ICC Analyst	Inspection Unit(s)	Man Day(s)	Inspection Date(s)	Contact(s)
Design Testing and Construction	Glasford	Jim Watts	Glasford Storage	1	8/13/2013	Chuck Tebbe, Harvey Schofield, J.R. Jennings

Statement of Activities

On August 13, 2013, Staff conducted a construction audit at the Ameren Glasford Storage Facility. The purpose of the inspection was to determine compliance with the code sections identified on the attached inspection forms. KS Energy Services has been contracted by Ameren Illinois to replace multiple segments of the storage field transmission system piping, install pig launcher/receiver's and install or replace drips used to catch the liquids produced during periods of withdrawal. The area audited is located in the south segment of the field near the Cilco #7 well. During the inspection the welders were pre-fabing drips and above ground piping for the pig launcher/receiver to be installed at Cilco #7 well site and at other locations in the field. Staff performed voltage and amperage tests while observing the welding and determined they were within the limitations prescribed in Ameren Welding procedure #003 for butt welding of 12 and 16 inch X52 piping and F01 for fillet welding. The welder qualifications were reviewed as part of the inspection and determined they were currently qualified for the processes being utilized during the inspection. Staff confirmed the contractor personnel were also currently qualified for the tasks observed being performed.

ISSUE(S) FOUND:

NO ISSUES FOUND.

ISSUE(S) CORRECTED:

NO ISSUES CORRECTED.

NOTICE OF AMENDMENT(S) FOUND:

NO NOAs FOUND.

NOA(S) CORRECTED:

NO NOAs CORRECTED.

NOTICE OF PROBABLE VIOLATION(S) FOUND:

NO NOPVs FOUND.

NOPV(S) CORRECTED:

NO NOPVs CORRECTED.